



Declaration of conformity

For the following equipment:

Product Name: LED Driver

Model Designation: PCD/PLD-40-xB(x=350,500,700,1050,1400,1750)

PCD/PLD-60-xB(x=500,700,1050,1400,1750,2000,2400);PCD-60-1500BGAM

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were

applied:

RoHS Directive (2011/65/EU)

Energy-Related Products Directive (2009/125/EC)
Implementing measure COMMISSION REGULATION(EC) No 1194/2012

Low Voltage Directive (2014/35/EU):

EN 61347-1:2015 EN61347-2-13:2014/A1:2017

EN 62384:2006+A1:2009 ENEC certificate No: 35-103241

Electromagnetic Compatibility Directive (2014/30/EU):

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

EN55015:2013+A1:2015

Harmonic current	EN61000-3-2:2014		Class C(≧75% load)			
Voltage flicker	EN61000-3-3:2013					
EMS (Electro-Magnetic Susceptibility)						
EN61547:2009						
ESD air	EN61000-4-2:2009	Level 3	8KV			
ESD contact	EN61000-4-2:2009	Level 2	4KV			
RF field susceptibility	EN61000-4-3:2006+A1:2008+A2:2010	Level 2	3V/m			
EFT bursts	EN61000-4-4:2012	Level 2	1KV/5KHz			
Surge susceptibility	EN61000-4-5:2014	Level 4	2KV/Line-Line			

Magnetic field immunity	EN61000-4-8:2010		Level 2 3A/m	
Voltage dip, interruption	EN61000-4-11:2004	30% dip 10 periods	100% interruptions 0.5 periods	
Noto:				

Component power supply will be operated with a final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

Tests above are only to be performed with LEDs.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

EN61000-4-6:2014

To fulfill requirements of the latest ErP regulation for lighting fixtures, this LED power supply can only be used behind a switch without permanently connected to the mains.

This Declaration is effective from serial number HB8xxxxxxx

Person responsible for marking this declaration:

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

Conducted susceptibility

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 248, Taiwan

(Manufacturer Address)

Johnny Huang/Manager, Certification center:

(Name / Position)

Alex Tsai/Director, Marketing Department:

Level 2

(Name / Position)

(Signature)

Taiwan

Mar. 27th, 2018

(Place)

(Date)

(Signature)